

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: 181

DATE: 20-5-2026

It is certified that inspection team headed by Sri Malatesh P Executive Engineer Rural drinking water and sanitization division Haveri inspected the **Laxman Keshappa Sheshagiri English Medium Higher Primary and High school Akkialur Tq;Hangal, Dt;Haveri** on and found that **Laxman Keshappa Sheshagiri English Medium Primary and High school Akki Alur** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per rooms prescribed by the central/state/U.T.govt.

The above is valid for one year



Signature with seal: Malatesh P **EXECUTIVE ENGINEER**
Rural Drinking Water & Sanitation
Executive Engineer **Division, Haveri.**

Rural drinking water & sanitization
division Haveri.

Copy to,

The chairman, Shri Laxman Keshappa Sheshagiri English Medium Higher Primary and High school
Akkialur

- The filled up certificate should be the either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original certificate as a single pdf.



Secretary

Jnana Bharati Vidyavardhak Sangh (R)
AKKI-ALUR-581102.
Tq: Hangal Dist. Haveri



HEAD MASTER

Laxman Keshappa Sheshagiri
English Medium Higher Primary &
High School, Akki Alur-581102.
Tq: Hangal Dist: Haveri



HAVERI DISTRICT WATER QUALITY TESTING LABORATORY,
RURAL DRINKING WATER AND SANITATION DEPARTMENT-HAVERI,
VIDYANAGAR OLD ZP COMPOUND,HAVERI, KARNATAKA, INDIA
e-mail: ee.rws.hvr@gmail.com / rdwsd.wqmsh.haverilab@gmail.com
Phone No:08375- 237129

District Name: Haveri

Laboratory Name: Division Laboratory

TEST REPORT

School Address:Jnana Bharti Vidyavardhak Sangh(R)
Shri Lakshman Keshappa Sheshagiri English
Medium Higher Primary And High School
Akkialur
Taluk: Hangal
District: Haveri

Report date:1 .05.2026
Report Number:22
Sample receipt date:13.05.2026
Sample code:HAN26MAYBW22
Date of Sampling:13.05.2026
Analysis start date:14.05.2026
Analysis completion date:15.05.2026
Sample Collection method: Manual for Water
Quality Analysis,RDWSD,GoK

Sample Particulars:Borewell Water

Sample quantity: 1000 ml

Sl. No	Test	Results	Acceptable Limit IS 10500:2012 RA 2023	Permissible Limit 10500:2012 RA 2023	Test Method
--------	------	---------	--	--------------------------------------	-------------

Description: Colourless Liquid

1.	pH Value @25°C	7.02	6.5-8.5	No Relaxation	IS 3025(Part 11):2022
2.	Specific Conductance $\mu S/cm$ at @25°C	225	-	-	IS 3025(Part 14):2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):2018
4.	Colour, Hazen	5	5	15	IS 3025 (Part-4):2021
5.	Turbidity,NTU	0.6	1	5	IS 3025 (Part 10):2023
6.	Total Dissolved Solids,mg/l @ 180°C,mg/l	136	500	2000	IS 3025 (Part 16):2023
7.	Total Alkalinity as $CaCO_3$,mg/l	31.84	200	600	IS 3025 (Part 23):2023
8.	Total Hardness as $CaCO_3$,mg/l	84.92	200	600	IS 3025 (Part 21):2019
9.	Calcium as Ca,mg/l	21.04	75	200	IS 3025 (Part 40): 2024
10.	Magnesium as Mg,mg/l	7.85	30	100	IS 3025 (Part 46): 2023
11.	Chloride as Cl,mg/l	42.40	250	1000	IS 3025 (Part 32):2025
12.	Sulphate as SO_4 ,mg/l	6.60	200	400	IS 3025 (Part 24 Sec-1):2022
13.	Fluoride as F,mg/l	0.106	1	1.5	APHA 24 rd Edition:4500F-D:2023
14.	Nitrate as NO_3 ,mg/l	3.12	45	No Relaxation	APHA 24 rd Edition:4500NO ₃ -B:2023
15.	Iron as Fe,mg/l	0.116	1	No Relaxation	IS 3025 (Part 53):2024

Remark: The above tested parameters conforms that they are within the acceptable limit as per the specification of IS10500:2012 RA :2023

Verified by:
Junior Analyst:Bhagyashree N Bangigoudra

Authorized Signatory:
Technical Manager :Bhuvaneshwari.R.Patil
RDWSD/WQMSP/TeR/01

Secretary

Jnana Bharati Vidyavardhak Sangh (R)
AKKI-ALUR-581102.

Tq: Hangal Dist: Haveri

HEAD MASTER

Lakshman Keshappa Sheshagiri
English Medium Higher Primary
High School, Akki Alur-581102.

Tq: Hangal Dist: Haveri